| Model(s): | | Outdoor unit: MHA-V14W/D2RN8-B Indoor unit: HB-A160/C***GN8-B, HBT-A160/240CD***GN8-B | | | | | |
|--|---|--|------|--|-------------------|------------|-------------------|
| Air-to-water heat pump: | | YES | | | | | |
| Water-to-water heat pump: | | NO | | | | | |
| Brine-to-water heat pump: | | NO | | | | | |
| Low-temperature heat pump: | | NO | | | | | |
| Equipped with a supplementary heat | er: | | | YES | | | |
| Heat pump combination heater: | | | | YES | | | |
| Declared climate condition: | | | | AVERAGE | | | |
| Parameters are declared for medium | -temperature | e application | ١. | | | | |
| ltem | Symbol | Value | Unit | Item | Symbol | Value | Uni |
| Rated heat output (*) | Prated | 12.1 | kW | Seasonal space heating energy efficiency | ηs | 135.6 | % |
| Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj | | | | Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Ti | | | |
| | Pdh | 10.68 | kW | Tj = -7°C | COPd | 2.01 | - |
| <u>., </u> | Pdh | 6.86 | kW | Tj = 2°C | COPd | 3.43 | - |
| Tj = 7°C | Pdh | 4.63 | kW | Tj = 7°C | COPd | 4.66 | - |
| Tj = 12°C | Pdh | 3.31 | kW | Tj = 12°C | COPd | 6.13 | - |
| Tj = l2 C Tj = bivalent temperature | | | | Tj = bivalent temperature | COPd | | - |
| Tj = operating limit | Pdh Pdh | 10.68 | kW | Tj = operating limit | COPd | 1.76 | - |
| <u> </u> | Pdh | 9.19 | kW | , , <u> </u> | COPd | 1.76 | - |
| For air-to-water heat pumps: Tj = -15°C Bivalent temperature | Tbiv | -7 | °C | For air-to-water heat pumps: Tj = -15°C For air-to-water heat pumps: Operation limit temperature | TOL | -10 | °C |
| Cycling interval capacity for heating | Pcych | - | kW | Cycling interval efficiency | COPcyc | | - |
| Degradation co-efficient (**) | Cdh | 0.9 | | Heating water operating limit temperature | WTOL | 60 | °C |
| Power consumption in modes other than a | I active mode | | | Supplementary heater | | | |
| Off mode | Poff | 0.020 | kW | | | | |
| Standby mode | Psb | 0.020 | kW | Rated heat output (**) | Psup | 1.40 | kW |
| Thermostat-off mode | Pto | 0.030 | kW | To a of an annuity of | | | |
| Crankcase heater mode | Pck | 0.000 | kW | Type of energy input | | Electrical | |
| Other items | | | | | | | |
| Capacity control | variable | | | For air-to-water heat pumps: Rated air flow rate, outdoors | - | 4060 | m³/h |
| Sound power level, indoors/outdoors | L _{WA} | 43 ^{a)} /65 44 ^{b)} /65 | dB | For water-or brine-to-water heat pumps: Rated brine or water flow rate, outdoor heat exchanger | - | - | m ³ /h |
| Annual energy consumption | Q _{HE} | 7203 | kWh | | | | |
| For heat pump combination heater: | | | | | | | |
| Declared load profile | | XL | | Water heating energy efficiency | η_{wh} | 123 | % |
| Daily electricity consumption | Q _{clec} | 6.35 | kWh | Daily fuel consumption | Q _{fuel} | - | kWI |
| Annual electricity consumption | AEC | 1360 | kWh | Annual fuel consumption | AFC | - | GJ |
| Contact details | GD Midea Heating & Ventilating Equipment Co. Ltd (Penglai industry road, Beijiao, Shunde, Foshan, Guangdong, P.R China) | | | | | | |

 ^(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.
 a) Represents: HB-A160/C***GN8-B
 b) Represents: HBT-A160/240CD***GN8-B